



Department of
Building and Housing
Te Tari Kaupapa Whare

Extract from the New Zealand Building Code:

Clauses C1-C6 Protection from Fire

Clause A3 Building Importance Levels



This document contains extracts of the New Zealand Building Code Clauses C1–C6 Protection from Fire and A3 Building Importance Levels. The full Building Code is contained in Schedule 1 of the Building Regulations 1992. These regulations can be downloaded from www.legislation.govt.nz

People using this document should check on a regular basis whether new versions have been published. The current version can be downloaded from www.dbh.govt.nz/compliance-documents
Users should make themselves familiar with the preface to the New Zealand Building Code Handbook, which describes the building controls system in New Zealand and the Building Code.

Defined words (italicised in the text) are explained in the Building Code Clause A2 Interpretation.

Enquiries about the content of this document should be directed to:



Department of
Building and Housing
Te Tari Kaupapa Whare

Department of Building and Housing

PO Box 10-729, Wellington.

Telephone 0800 242 243

Fax 04 494 0290

Email: info@dbh.govt.nz

Regulations are available from www.legislation.govt.nz

New Zealand Government

C1—OBJECTIVES OF CLAUSES C2 TO C6 (PROTECTION FROM FIRE)

Provisions

The objectives of clauses C2 to C6 are to:

- (a) safeguard people from an unacceptable risk of injury or illness caused by *fire*,
- (b) protect *other property* from damage caused by *fire*, and
- (c) facilitate firefighting and rescue operations.

Limit on application

**C2—PREVENTION OF FIRE
OCCURRING****Provisions****Limit on application****FUNCTIONAL REQUIREMENT**

C2.1 Fixed appliances using controlled combustion and other fixed equipment must be designed, constructed, and installed in *buildings* in a way that reduces the likelihood of illness or injury due to *fire* occurring.

PERFORMANCE

C2.2 The maximum surface temperature of *combustible building materials* close to fixed appliances using controlled combustion and other fixed equipment when operating at their design level must not exceed 90°C.

C2.3 Fixed appliances using controlled combustion and other fixed equipment must be designed, constructed and installed so that there is a low probability of explosive or hazardous conditions occurring within any spaces in or around the *building* that contains the appliances.

C3—FIRE AFFECTING AREAS BEYOND THE FIRE SOURCE

Provisions

FUNCTIONAL REQUIREMENT

C3.1 *Buildings* must be designed and constructed so that there is a low probability of injury or illness to persons not in close proximity to a *fire source*.

C3.2 *Buildings* with a *building height* greater than 10 m where upper floors contain sleeping uses or *other property* must be designed and constructed so that there is a low probability of external vertical fire spread to upper floors in the *building*.

C3.3 *Buildings* must be designed and constructed so that there is a low probability of *fire* spread to *other property* vertically or horizontally across a *relevant boundary*.

Limit on application

Clause C3.2 does not apply to importance level 1 *buildings*.

C3—FIRE AFFECTING AREAS BEYOND THE FIRE SOURCE (continued)**Provisions****Limit on application****PERFORMANCE**

C3.4 (a) materials used as internal surface linings in the following areas of *buildings* must meet the performance criteria specified below:

Clause C3.4 does not apply to *detached dwellings*, within *household units* in *multi-unit dwellings*, or *outbuildings* and *ancillary buildings*.

Area of <i>building</i>	Performance determined under conditions described in ISO 9705: 1993	
	<i>Buildings not protected with an automatic fire sprinkler system</i>	<i>Buildings protected with an automatic fire sprinkler system</i>
Wall/ceiling materials in sleeping areas where care or detention is provided	Material Group Number 1-S	Material Group Number 1 or 2
Wall/ceiling materials in exitways	Material Group Number 1-S	Material Group Number 1 or 2
Wall/ceiling materials in all <i>occupied spaces</i> in importance level 4 <i>buildings</i>	Material Group Number 1-S	Material Group Number 1 or 2
Internal surfaces of ducts for <i>HVAC systems</i>	Material Group Number 1-S	Material Group Number 1 or 2
Ceiling materials in crowd and sleeping uses except <i>household units</i> and where care or detention is provided	Material Group Number 1-S or 2-S	Material Group Number 1 or 2
Wall materials in crowd and sleeping uses except <i>household units</i> and where care or detention is provided	Material Group Number 1-S or 2-S	Material Group Number 1, 2, or 3
Wall/ceiling materials in occupied spaces in all other locations in <i>buildings</i> , including <i>household units</i>	Material Group Number 1, 2, or 3	Material Group Number 1, 2, or 3
External surfaces of ducts for <i>HVAC systems</i>	Material Group Number 1, 2, or 3	Material Group Number 1, 2, or 3
Acoustic treatment and pipe insulation within airhandling plenums in sleeping uses	Material Group Number 1, 2, or 3	Material Group Number 1, 2, or 3

C3—FIRE AFFECTING AREAS BEYOND THE FIRE SOURCE (continued)

Provisions

(b) floor surface materials in the following areas of *buildings* must meet the performance criteria specified below:

Limit on application

Area of <i>building</i>	Minimum critical radiant flux when tested to ISO 9239-1: 2010	
	<i>Buildings</i> not protected with an automatic fire sprinkler system	<i>Buildings</i> protected with an automatic fire sprinkler system
Sleeping areas and exitways in <i>buildings</i> where care or detention is provided	4.5 kW/m ²	2.2 kW/m ²
Exitways in all other <i>buildings</i>	2.2 kW/m ²	2.2 kW/m ²
<i>Firecells</i> accommodating more than 50 persons	2.2 kW/m ²	1.2 kW/m ²
All other occupied spaces except <i>household units</i>	1.2 kW/m ²	1.2 kW/m ²

(c) suspended flexible fabrics and membrane structures used in the construction of *buildings* must have properties resulting in a low probability of injury or illness to persons not in close proximity to a *fire source*.

C3.5 *Buildings* must be designed and constructed so that fire does not spread more than 3.5 m vertically from the *fire source* over the external cladding of multi-level *buildings*.

C3.6 *Buildings* must be designed and constructed so that in the event of *fire* in the building the received radiation at the *relevant boundary* of the property does not exceed 30 kW/m² and at a distance of 1 m beyond the *relevant boundary* of the property does not exceed 16 kW/m².



C3—FIRE AFFECTING AREAS BEYOND THE FIRE SOURCE (continued)

Provisions

C3.7 External walls of *buildings* that are located closer than 1 m to the *relevant boundary* of the property on which the *building* stands must either:

- (a) be constructed from materials which are not *combustible building materials*, or
- (b) for *buildings* in importance levels 3 and 4, be constructed from materials that, when subjected to a radiant flux of 30 kW/m², do not ignite for 30 minutes, or
- (c) for *buildings* in Importance Levels 1 and 2, be constructed from materials that, when subjected to a radiant flux of 30 kW/m², do not ignite for 15 minutes.

C3.8 *Firecells* located within 15 m of a *relevant boundary* that are not protected by an automatic *fire* sprinkler system, and that contain a *fire load* greater than 20 TJ or that have a floor area greater than 5,000 m² must be designed and constructed so that at the time that firefighters first apply water to the *fire*, the maximum radiation flux at 1.5 m above the floor is no greater than 4.5 kW/m² and the smoke layer is not less than 2 m above the floor.

C3.9 *Buildings* must be designed and constructed with regard to the likelihood and consequence of failure of any *fire safety* system intended to control *fire* spread.

Limit on application

C4—MOVEMENT TO PLACE OF SAFETY

Provisions

FUNCTIONAL REQUIREMENT

C4.1 *Buildings* must be provided with:

- (a) effective means of giving warning of *fire*, and
- (b) visibility in *escape routes* complying with clause F6.

C4.2 *Buildings* must be provided with means of escape to ensure that there is a low probability of occupants of those buildings being unreasonably delayed or impeded from moving to a *place of safety* and that those occupants will not suffer injury or illness as a result.

PERFORMANCE

C4.3 The *evacuation time* must allow occupants of a building to move to a *place of safety* in the event of a fire so that occupants are not exposed to any of the following:

- (a) a *fractional effective dose* of carbon monoxide greater than 0.3:
- (b) a *fractional effective dose* of thermal effects greater than 0.3:
- (c) conditions where, due to smoke obscuration, visibility is less than 10 m except in rooms of less than 100 m² where visibility may fall to 5 m.

C4.4 Clause C4.3(b) and (c) do not apply where it is not possible to expose more than 1 000 occupants in a *firecell* protected with an automatic *fire* sprinkler system.

C4.5 Means of escape to a *place of safety* in *buildings* must be designed and constructed with regard to the likelihood and consequence of failure of any *fire safety systems*.

Limit on application

C5—ACCESS AND SAFETY FOR FIREFIGHTING OPERATIONS

Provisions

FUNCTIONAL REQUIREMENT

C5.1 *Buildings* must be designed and constructed so that there is a low probability of firefighters or other emergency services personnel being delayed in or impeded from assisting in rescue operations and performing firefighting operations.

C5.2 *Buildings* must be designed and constructed so that there is a low probability of illness or injury to firefighters or other emergency services personnel during rescue and firefighting operations.

PERFORMANCE

C5.3 *Buildings* must be provided with access for fire service vehicles to a hard-standing from which there is an unobstructed path to the *building* within 20 m of:

- (a) the firefighter access into the *building*, and
- (b) the inlets to automatic fire sprinkler systems or fire hydrant systems, where these are installed.

C5.4 Access for fire service vehicles in accordance with clause C5.3 must be provided to more than 1 side of *firecells* greater than 5,000 m² in floor area that are not protected by an automatic fire sprinkler system.

C5.5 *Buildings* must be provided with the means to deliver water for firefighting to all parts of the *building*.

C5.6 *Buildings* must be designed and constructed in a manner that will allow firefighters, taking into account the firefighters' personal protective equipment and standard training, to:

- (a) reach the floor of fire origin,
- (b) search the general area of fire origin, and
- (c) protect their means of egress.

Limit on application

Performance requirements in clauses C5.3 to C5.8 do not apply to *backcountry huts*, *detached dwellings*, within *household units* in *multi-unit dwellings*, or to *outbuildings*, and *ancillary buildings*.

**C5—ACCESS AND SAFETY FOR
FIREFIGHTING OPERATIONS** (continued)

Provisions

C5.7 *Buildings* must be provided with means of giving clear information to enable firefighters to:

- (a) establish the general location of the *fire*,
- (b) identify the *fire safety systems* available in the *building*, and
- (c) establish the presence of *hazardous substances* or process in the *building*.

C5.8 Means to provide access for and safety of firefighters in *buildings* must be designed and constructed with regard to the likelihood and consequence of failure of any *fire safety systems*.

Limit on application

C6—STRUCTURAL STABILITY**Provisions****Limit on application****FUNCTIONAL REQUIREMENT**

C6.1 Structural systems in *buildings* must be constructed to maintain structural stability during *fire* so that there is:

- (a) a low probability of injury or illness to occupants,
- (b) a low probability of injury or illness to *fire* service personnel during rescue and firefighting operations, and
- (c) a low probability of direct or consequential damage to adjacent *household units* or *other property*.

PERFORMANCE

C6.2 Structural systems in *buildings* that are necessary for structural stability in *fire* must be designed and constructed so that they remain stable during *fire* and after *fire* when required to protect *other property* taking into account:

- (a) the *fire* severity,
- (b) any automatic fire sprinkler systems within the *buildings*,
- (c) any other active *fire safety systems* that affect the *fire* severity and its impact on structural stability, and
- (d) the likelihood and consequence of failure of any *fire safety systems* that affect the *fire* severity and its impact on structural stability.

C6.3 Structural systems in *buildings* that are necessary to provide firefighters with safe access to floors for the purpose of conducting firefighting and rescue operations must be designed and constructed so that they remain stable during and after *fire*.

C6.4 Collapse of building elements that have lesser *fire* resistance must not cause the consequential collapse of elements that are required to have a higher *fire* resistance.

CLAUSE A3—BUILDING IMPORTANCE LEVELS

For the purposes of clause C, a *building* has one of the importance levels set out below:

Importance level	Description of building type	Specific structure
Importance level 1	<i>Buildings</i> posing low risk to human life or the environment, or a low economic cost, should the <i>building</i> fail. These are typically small non-habitable <i>buildings</i> , such as sheds, barns, and the like, that are not normally occupied, though they may have occupants from time to time.	<ul style="list-style-type: none"> • Ancillary <i>buildings</i> not for human habitation • Minor storage facilities • Backcountry huts
Importance level 2	<i>Buildings</i> posing normal risk to human life or the environment, or a normal economic cost, should the <i>building</i> fail. These are typical residential, commercial, and industrial <i>buildings</i> .	<ul style="list-style-type: none"> • All <i>buildings</i> and facilities except those listed in importance levels 1, 3, 4, and 5
Importance level 3	<i>Buildings</i> of a higher level of societal benefit or importance, or with higher levels of risk-significant factors to <i>building</i> occupants. These <i>buildings</i> have increased performance requirements because they may house large numbers of people, vulnerable populations, or occupants with other risk factors, or fulfil a role of increased importance to the local community or to society in general.	<ul style="list-style-type: none"> • <i>Buildings</i> where more than 300 people congregate in 1 area • <i>Buildings</i> with primary school, secondary school, or daycare facilities with a capacity greater than 250 • <i>Buildings</i> with tertiary or adult education facilities with a capacity greater than 500 • Health care facilities with a capacity of 50 or more residents but not having surgery or emergency treatment facilities • Jails and detention facilities • Any other <i>building</i> with a capacity of 5 000 or more people • <i>Buildings</i> for power generating facilities, water treatment for potable water, wastewater treatment facilities, and other public utilities facilities not included in importance level 4

CLAUSE A3—BUILDING IMPORTANCE LEVELS (continued)

Importance level	Description of building type	Specific structure
Importance level 3 (continued)		<ul style="list-style-type: none"> • <i>Buildings</i> not included in importance level 4 or 5 containing sufficient quantities of highly toxic gas or explosive materials capable of causing acutely hazardous conditions that do not extend beyond property boundaries
Importance level 4	<i>Buildings</i> that are essential to post-disaster recovery or associated with hazardous facilities.	<ul style="list-style-type: none"> • Hospitals and other health care facilities having surgery or emergency treatment facilities • <i>Fire</i>, rescue, and police stations and emergency vehicle garages • <i>Buildings</i> intended to be used as emergency shelters • <i>Buildings</i> intended by the owner to contribute to emergency preparedness, or to be used for communication, and operation centres in an emergency, and other facilities required for emergency response • Power generating stations and other utilities required as emergency backup facilities for importance level 3 structures • <i>Buildings</i> housing highly toxic gas or explosive materials capable of causing acutely hazardous conditions that extend beyond property boundaries • Aviation control towers, air traffic control centres, and emergency aircraft hangars • <i>Buildings</i> having critical national defence functions • Water treatment facilities required to maintain water pressure for fire suppression

CLAUSE A3—BUILDING IMPORTANCE LEVELS (continued)

Importance level	Description of building type	Specific structure
Importance level 4 (continued)		<ul style="list-style-type: none"> • Ancillary <i>buildings</i> (including, but not limited to, communication towers, fuel storage tanks or other structures housing or supporting water or other <i>fire</i> suppression material or equipment) required for operation of importance level 4 structures during an emergency
Importance level 5	<i>Buildings</i> whose failure poses catastrophic risk to a large area (eg, 100 km ²) or a large number of people (eg, 100 000).	<ul style="list-style-type: none"> • Major dams • Extremely hazardous facilities

