

Note:

Notice #: RN-10049



**MINISTRY OF BUSINESS,
INNOVATION & EMPLOYMENT**
HĪKINA WHAKATUTUKI

This legislation is administered by the Ministry of Business, Innovation and Employment. For more information please see:

Website: <http://www.building.govt.nz>

Contact phone: 0800 24 22 43

Contact address: 15 Stout Street, Wellington, New Zealand 6011

Building (Product Recognition WaterMark Metallic and Non-Metallic In-Line Valves for Water Supply Systems) Amendment Notice 2026: RN-10049

This amendment notice is made under section 272HA of the Building Act 2004 by
Simon Thomas, Head of Building System Delivery and Assurance at the Ministry of
Business, Innovation and Employment—

(a) acting under the delegated authority of the Chief Executive of the Ministry of Business,
Innovation and Employment, and

(b) after being satisfied of the matters set out in section 272HA(2).

Contents

	Page
1 Title	1
2 Commencement	2
3 Principal notice	2
4 Schedule 1 amended	2

Notice

1 Title

This is the Building (Product Recognition WaterMark Metallic and Non-Metallic In-Line Valves for Water Supply Systems) Amendment Notice 2026: RN-10049.

2 Commencement

This notice comes into force on 28 September 2026.

3 Principal notice

- (1) This notice amends the Building (Product Recognition WaterMark Metallic and Non-Metallic In-Line Valves for Water Supply Systems) Notice 2026: RN-10049.

4 Schedule 1 amended

- (1) In Schedule 1, table, replace:

Standard	Standard Title	AS/NZS 3500 series link	Equivalent acceptable solution or verification method	Building Code performance clauses
Watermark Technical Specifications – WMTS 012:2018	In-line valves for use in plumbing water supply systems– Miscellaneous types metallic and non- metallic	N/A	B2/VM1, G10/AS1, G12/AS1	B2.3.1(b), F2.3.1, G10.3.1(a) and (b), G12.3.2 (c)

with:

Standard	Standard Title	AS/NZS 3500 series link	Equivalent acceptable solution or verification method	Building Code performance clauses
Watermark Technical Specifications – WMTS 012:2018	In-line valves for use in plumbing water supply systems– Miscellaneous types metallic and non- metallic	N/A	B2/AS1, F2/AS1, G12/AS1	B2.3.1(b), F2.3.1, G12.3.2 (a), (b) and (c)

- (2) In Schedule 1, table, after:

"The building products recognised by this notice must be installed according to the conditions and limitations specified in the product certificate for the relevant building product, as set out in Schedule 1 of this notice."

insert:

"Where applicable all copper alloy products to be used in contact with drinking water certified under this standard will need to meet the lead-free requirements, as outlined in G12/AS1, from 1 May 2026. To be compliant the submitter must provide a valid lead-free test certificate from an IANZ-accredited body or equivalent to NSF/ANSI/CAN 372:2020. This must be provided with the building consent application for it to be accepted as establishing compliance with the Building Code."

(3) In Schedule 1, table, replace:

(a) at row 26, "Intertek SAI Global Certification Services Pty Ltd WMK25971 19/06/2026"

with "[Revoked on 28 September 2026 by the Building (Product Recognition WaterMark Metallic and Non-Metallic In-Line Valves for Water Supply Systems) Amendment Notice 2026: RN-10049]".

(4) In Schedule 1, table, replace:

(a) "08/06/2030" at row 15 with "06/08/2030"; and

(b) "03/02/2029" at row 27 with "03/02/2031"; and

(c) "08/03/2026" at row 32 with "08/03/2031".

(5) In Schedule 1, table, at row 34, delete the "S" before "Intertek".

Made at Wellington on: 7 September 2026

Simon Thomas, Head of Building System Delivery and Assurance at the Ministry of
Business, Innovation and Employment
acting under the delegated authority of the Chief Executive of the Ministry of Business,
Innovation and Employment

Explanatory note

This note is not part of the notice but is intended to indicate its general effect.

This notice, which comes into force on 28 September 2026, amends the Building (Product Recognition WaterMark Metallic and Non-Metallic In-Line Valves for Water Supply Systems) Notice 2026: RN-10049.

It specifies equivalent acceptable solution or verification methods and relevant Building Code performance clauses, removes certificates that have expired and updates the expiry dates of some certificates.

This is secondary legislation issued under the authority of the Legislation Act 2019 .	
Title	<i>Building (Product Recognition WaterMark Metallic and Non-Metallic In-Line Valves for Water Supply Systems) Amendment Notice 2026: RN-10049</i>
Principal or amendment	Amendment
Consolidated version	No
Empowering Act and provisions	Building Act 2004 section 272HA
Maker name	Simon Thomas, Head of Building System Delivery and Assurance at the Ministry of Business, Innovation and Employment acting under the delegated authority of the Chief Executive of the Ministry of Business, Innovation and Employment
Administering agency	Ministry of Business, Innovation and Employment
Date made	7 September 2026
Publication date	21 September 2026
Notification date	21 September 2026
Commencement date	28 September 2026
Related instruments	Building (Product Recognition WaterMark Metallic and Non-Metallic In-Line Valves for Water Supply Systems) Notice 2026: RN-10049