

2019/004: Decisions to refuse to issue a code compliance certificate and to issue a notice to fix in respect of a solid fuel heater

Document

Determination 2019/004

[PDF 202 KB]

<https://www.building.govt.nz/assets/Uploads/resolving-problems/determinations/2019/2019-004.pdf>

About this determination

Date issued: 18 February 2019

Primary Building Code clause: [C2 - Prevention of fire occurring \(https://www.building.govt.nz/building-code-compliance/c-protection-from-fire/c2-prevention-of-fire-occurring/\)](https://www.building.govt.nz/building-code-compliance/c-protection-from-fire/c2-prevention-of-fire-occurring/)

Primary topic: [Fire safety \(https://www.building.govt.nz/resolving-problems/resolution-options/determinations/determinations-issued/?keyword=&topic=Fire+safety&action_doSearch=Search#results#\)](https://www.building.govt.nz/resolving-problems/resolution-options/determinations/determinations-issued/?keyword=&topic=Fire+safety&action_doSearch=Search#results#)

Council: Christchurch City Council

Summary

Note: This determination is subject to clarification

This determination concerns an as-installed solid fuel heater installed without the clearance behind it that was described in the manufacturer's installation instructions. The determination considers the compliance of heater and a notice to fix issued in respect of this work.

View all determinations on this topic (https://www.building.govt.nz/resolving-problems/resolution-options/determinations/determinations-issued/?keyword=&topic=Fire+safety&action_doSearch=Search#results#)

[Back to determinations register \(https://www.building.govt.nz/resolving-problems/resolution-](https://www.building.govt.nz/resolving-problems/resolution-options/determinations/determinations-issued/determination-2019-004/)

[options/determinations/determinations-issued/](#)



**MINISTRY OF BUSINESS,
INNOVATION & EMPLOYMENT**
HĪKINA WHAKATUTUKI

New Zealand Government

